

রুরাল পাওয়ার কোম্পানী লিমিটেড
RURAL POWER COMPANY LIMITED

Corporate Office :
House # 19, Road # 1/B, Sector # 09
Uttara Model Town, Dhaka-1230.
Phone : 8912274, (PABX)
Fax : 88-02-8922526
Web : www.rpcl.org.bd
E-mail : rpcmd@dhaka.net
rpcl@dhaka.net

Memo no: 27.26.0000.003.14.001.11.516

Dated: 24/06/2013

To,

✓ Concord Pragatee Consortium Ltd.
5/10 Lalmatia Housing Society
Block-D, Dhaka-1207
Fax: +88-02-8116513
Email: cpcl@dhaka.net


**Subject: Issuance of Provisional Acceptance Certificate for 25MW Dual-Fuel
Raozan Power Plant Project.**

Ref.: Contract no. PUR-003/2010, dated: 23/03/2011

Dear Sir,

With reference to the above mentioned subject and reference, this is to inform you that Provisional Acceptance Certificate (PAC) for EPC contract of 25MW Dual-Fuel Raozan Power Plant Project is enclosed herewith.


Thanking you.


24.06.13

(Shankar Chandra Barman)
Director (Technical)
Rural Power Company Ltd.

Copy to:

1. Managing Director, RPCL, Dhaka.
2. Director(Finance), RPCL, Dhaka
3. Project Director, RPP, Raozan, Chittagong.
4. Engineers & Consultants Bangladesh Ltd. (ECBL), Dhaka
5. Office copy.



রুরাল পাওয়ার কোম্পানী লিমিটেড
RURAL POWER COMPANY LIMITED

Corporate Office :
House # 19, Road # 1/B, Sector # 09
Uttara Model Town, Dhaka-1230.
Phone : 8912274, (PABX)
Fax : 88-02-8922526
Web : www.rpcl.org.bd
E-mail : rpcmd@dhaka.net
rpcl@dhaka.net

Memo no: 27.26.0000.004.06.009.13.514

Date: 24/06/2013


Provisional Acceptance Certificate

"25MW Dual-Fuel Raozan Power Plant Project (HFO/Gas Fired Engine Generating sets) having net Power output 25.812MW at site conditions (35°C, 1.013 bar, 98% RH) at Chittagong under Construction of 25MW Dual-Fuel Raozan Power Plant Project of RPCL"

As per contract Document Vol^m 2 of 3 (General Conditions) clause no.-66 (Contract no.-PUR-003/2010, dated:23/03/2011)


- A. Name of the Project: 25MW Dual-Fuel Raozan Power Plant Project (HFO/Gas Fired Engine Generating sets).
- B. Location: Noapara, Raozan, Chittagong.
- C. Date Of Performance Test: Initial Commercial Operation (ICO) started on 02/05/2013 and completed on 25.05.2013. Performance and Acceptance Test was conducted on 02/06/2013.
- D. This is to certify that 25MW Dual-Fuel Raozan Power Plant Project has completed its initial commercial operation satisfactorily as per clause no.-16.3.2(3) of contract Document vol-2 of 3 of Contract no.- PUR-003/2010 dated: 23/03/2011 as well as Performance and Acceptance test for output and heat rate of engine sets as per clause no.-16.3.2(4) on 02/06/2013. Warranty period for the plant starts from the effective date of PAC as per contract.
- E. Remarks: (a) Effective date of this PAC will be on 02/05/2013 (Starting Date of ICO).
(b) Deficiencies/Deviations as mentioned in the attached Punch list shall be completed/rectified by Concord Pragottee Consortium Ltd. (CPCL) not later than 100 days from issuance of this certificate to the full and final satisfaction of RPCL authority.

The issuance of this certificate shall not be construed as a release to the contractor from any contractual liability or responsibility.


24.06.2013

(Mir Md. Zinnat Ali)
Project Director

25MW Dual-Fuel Raozan Power Plant Project
Rural Power Company Ltd


24.06.13

(Shankar Chandra Barman)
Director (Technical)
Rural Power Company Ltd


24.06.2013
(Md. Abdus Sabur)
Managing Director
Rural Power Company Ltd